
MD cooling tower

engineering data and specifications



MD5008

8.5' x 9' Nominal Cell Size



MD5008

8.5' x 9' Nominal Cell Size

Table Data Per Cell

| Model note 2 | Nominal Tons note 3 | Motor hp | Dimensions | | Design Operating | Shipping Weight lb | |
|-----------------|------------------------|--------------------|--------------------------|--------|---------------------|-----------------------|------------------|
| | | | H note 4 | А | Weight lb | Weight/Cell | Heaviest Section |
| MD5008KLC1L | 149 | 5 | 10'-9 ¹ ½6" | 7'-1%" | 6726 | 3752 | 1965 |
| MD5008MAC1L | 165 | 7.5 | | | | | |
| MD5008NAC1L | 179 | 10 | | | | | |
| MD5008PAC1L | 202 | 15 | | | | | |
| MD5008QAC1L | 216 | 20 | _ | | | | |
| MD5008KLD1L | 161 | 5 | | | | | |
| MD5008MAD1L | 180 | 7.5 | _ | | | | |
| MD5008NAD1L | 197 | 10 | 11'-9'1/16" | 8'-1%" | 7003 | 4029 | 2064 |
| MD5008PAD1L | 223 | 15 | _ | | | | |
| MD5008QAD1L | 239 | 20 | | | | | |
| MD5008KLF1L | 166 | 5 | | | | | |
| MD5008MAF1L | 189 | 7.5 | 12'-9 ¹ 1/16" | 9'-1%" | <mark>7280</mark> | 4306 | 2341 |
| MD5008NAF1L | 207 | 10 | | | | | |
| MD5008PAF1L | 234 | 15 | | | | | |
| MD5008QAF1L | 255 | 20 | | | | | |

Standard Layout Configuration Adds Per Cell

| Description | Model Suffix | Dimer | nsions | Design Operating Weight Ib | Shipping Weight |
|--------------------------|--------------|----------|--------|-------------------------------------|-----------------|
| Description | note 2 | H note 4 | Α | | Weight/Cell |
| SINGLE CELL | 1L | - | - | _ | _ |
| TWO OR MORE INLINE CELLS | 2L + | 91/8" | 91/8" | 46 | 46 |
| TWO CELLS BACK-TO-BACK | 2B | 91/8" | 91/8" | 46 | 46 |

NOTE

¹ Use this bulletin for preliminary layouts only. Obtain current drawings from your Marley sales representative. All table data is per cell.

² Last two characters of the model number indicate number of cells and cell configuration.

³ Nominal tons are based upon 95°F HW, 85°F CW, 78°F WB and 3 gpm/ton. The Marley **UPDATE** web-based selection software provides MD model recommendations based on specific design requirements.

⁴ Models with an Ultra Quiet Fan option require a taller fan cylinder, add 1'-11½" to this dimension for correct height.

Specifications

Specification Value

11.0 Cold Water Collection Basin:

<u>11.1</u> The collection basin shall be heavy-gauge galvanized steel and shall include the number and type of suction connections required to accommodate the outflow piping system shown on the plans. Suction connections shall be equipped with debris screens. A factory installed, float operated, mechanical make-up valve shall be included. An overflow and drain connection shall be provided in each cell of the tower. The basin floor shall slope toward the drain to allow complete flush out of debris and silt which may accumulate. Towers of more than one cell shall include steel flumes for flow and equalization between cells.

13.0 Warranty:

13.1 The MD cooling tower shall be free from defects in materials and workmanship for a period of eighteen (18) months from the date of shipment. ■ The MD tower design offers side-suction as standard. Bottom outlets may be supplied to accommodate a variety of piping schemes. Unless so specified, the tower you may be asked to approve may only be available with one type of suction connection requiring you to redesign your piping layout.

The sloping floor and low-level drain is valuable because it provides a way to achieve flush-out cleanability.